



Certificate of Analysis

Metals Testing – Water

Certificate No.: 21-54-55-60-2024

Sender: INSTITUTO DE CONSUMO ENERGÉTICO	
Address for results: INSTITUTO DE CONSUMO ENERGÉTICO	
Date of receiving: 17/01/2024	Testing termination date: 13/02/2024
FAX:	Phone:
Laboratory No.: 54-55-60	Sender No.:
Sample description: Lotus DY	

Results

Parameters	Units	Result before filtration in Lotus DY filter	Result after filtration in Lotus DY filter	Result after filtration in Lotus DY filter
Lab. No.		60	54	55
Cadmium (Cd)	µg/L	21	0.9	0.9
Tin (Sn)	µg/L	17	0.9	0.8
Lead (Pb)	µg/L	17	0.9	0.8
Molybdenum (Mo)	µg/L	22	1	1
Arsenic (As)	µg/L	18	0.9	0.9
Vandium (V)	µg/L	23	1.2	1.2
Titanium (Ti)	µg/L	15	1.3	1.5
Beryllium (Be)	µg/L	18	0.9	0.9

Comments:

Name of the tester: Hanny Fogel	Signature:
Name of the authorizer: Dr. E. Kalily	Position: Chem. Lab. Manager
Signature:	

End of certificate

The results refer only to the tested sample.

The Israel Authority for Accreditation is not responsible for the results performed by the laboratory, and the accreditation does not certify the tested sample.

It should be to refer to the whole certificate and it's forbidden to copy from it into other certificates.

Ministry of Health Laboratory seal
Public Health Laboratory
P.O. Box 99757 Haifa, Israel
Tel: 04-8619705 Fax: 04-8510172