

Ministry of Health
District Health Office
Public Health Laboratory, Haifa
15 Haparsim St, P.O.B. 9526, Haifa 35055
Tel: 04-8619803 Fax: 04-8510172



משרד הבריאות
לשכת הבריאות המחוזית
המעבדה לבריאות הציבור - חיפה
רח' הפרסים 15, ת"ד 9526, חיפה 35055
טל: 04-8619803 פקס: 04-8510172

Certificate of Analysis

Metals Testing – Water

Certificate No.: 21-440-444-2024

Sender: TIPA TECH	
Address for results: TIPA TECH	
Date of receiving: 25/03/2024	Testing termination date: 02/04/2024
FAX:	Phone:
Laboratory No.: 440-444	Sender No.:
Sample description: Lotus DY	

Results

Parameters	Units	Result before filtration in Lotus DY filter	Result after filtration in Lotus DY Filter (0% open)	Result after filtration in Lotus DY Filter (33% open)	Result after filtration in Lotus DY Filter (50% open)	Result after filtration in Lotus DY Filter (100% open)
Lab. No.		440	441	442	443	444
Magnesium (Mg)	µg/L	1270	1177	20838	31642	58613

Comments:

Name of the tester: Hanny Fogel	Signature:
Name of the authorizer: Dr. E. Kalily	Position: Chem. Lab. Manager
Signature:	

End of certificate

Laboratory seal

Ministry of Health
Public Health Laboratory
P.O. Box 99757 Haifa, Israel
Tel 04-8619705 Fax: 04-8510172

The results refer only to the tested sample.

The Israel Authority for Accreditation is not responsible for the results performed by the laboratory, and the accreditation does not certify the tested sample.

It should be to refer to the whole certificate and it's forbidden to copy from it into other certificates.